

Addendum #1

Flanged Connections will not have to be minimum of 300#. That is no longer a requirement.

Mark Harrison

City of Monroe